

NO 834/24

COMMUNITY HEALTH CENTRE
ULLANADU

SANITATION CERTIFICATE

I have inspected the building and premises of CHRISTHUJYOTHY ENGLISH MEDIUM SCHOOL, IV/227, KAYYOOR P. O, KOTTAYAM (Affiliation No. 930994) and certified that,

There is sufficient number of well ventilated class rooms and sufficient area is provided for open space and play ground. There are sufficient numbers of toilets and urinals kept separate for boys and girls and are kept clean. There is protected water supply and is provided with sufficient number of taps. The school and its premises are kept clean and tidy.

Hence on public health point of view the sanitary condition of the school is satisfactory.

CONDITIONS

1. Waste water should not be let into open drains.
2. Solid wastes should be disposed scientifically.
3. Any type of TOBACCO products are not allowed in the school compound.
4. Institution and surrounding are subjected to the periodic inspection of Health Authorities.
5. The water sources shall be treated with Bleaching powder@2.5gm/1000 Litres of water every six months.

Place : Ullanadu
Date: 20/06/2024



Bimal
HEALTH INSPECTOR
CHC ULLANADU
HEALTH INSPECTOR
CHC ULLANADU



QUALITY CONTROL SUB DISTRICT LABORATORY

KERALA WATER AUTHORITY,
PALA, KOTTAYAM

Telephone No. 04822 200675, Email: qcsdlpala@gmail.com

TEST REPORT

Report No: PL 1184 /PALA/09/2024	Date: 20.09.2024
----------------------------------	------------------

THE MANAGER KRISTHU JYOTHI ENGLISH MEDIUM SCHOOL KAYYOOR P.O PALA 686651	1.Date of Receipt	18.09.2024
	2.Sampling done by	CUSTOMER
	3.Sample Code	2024/QCSDL/PALA/PL5290
	4.Source of Sample	DRINKING WATER
	5.Sample Quantity	100 ML
	6.Sample conditions	ACCEPTABLE
	7.Test performing dates:	18.09.2024 TO 20.09.2024

BACTERIOLOGICAL ANALYSIS

Sl No.	Parameters	Acceptable limits as per –IS 10500-2012	Test Method	Result
1	Coliforms	Shall not be detected/100ml	IS 15185:2016	ABSENT
2	E.coli	Shall not be detected/100ml	IS 15185:2016	ABSENT

Test method

Coliforms: Membrane Filtration Method


E. coli: Membrane Filtration Method

Remarks:-

NB:- The result stated above related only to the sample(s) submitted for testing. This test Certificate shall not be reproduced except in full without the written approval of the laboratory

- *Samples will be retained only for 7 days after completion of analysis
- *Sampling is not done by the Lab

END OF REPORT



Authorized By

Shahana Sherief

Shahana

(Bacteriologist)